

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.**

No. 33Date: 31.1.25

It is certified that an inspection team headed by M. Swagatika
Food Safety Officer - Health & F.W Deptt./Bmc (Name of Officers
 with designation) from Health & F.W Deptt. (Name of
 Department/Office) inspected the D.A.V PUBLIC SCHOOL, Sitalganh
Plexi Road, Bhubaneswar (Name & Address of
 the School) on 27.01.2025 and found that the D.A.V PUBLIC SCHOOL
Sitalganh, Plexi Road Bhubaneswar (Name of school) has safe
 drinking water facilities for the students and members of staff of the institution and is maintaining
 the hygienic sanitation condition in the school building & the campus as per the norms
 prescribed by the Central/State/U.T Govt.

The above valid for a period of one year.

Signature with Seal : [Signature]

Name :

DR. DEEPAK K U BISA

Designation :

Health officer

To

PRINCIPALD.A.V Public School, Plexi RoadSitalganh, Bhubaneswar-2

(Name & Address of the Institution)

Health Officer
Bhubaneswar Municipal Corporation
Bhubaneswar

GOVERNMENT OF ODISHA
OFFICE OF THE JOINT DIRECTOR CUM CHIEF FOOD ANALYST
State Food Testing Laboratory, Convent Square, Near Ram Mandir, Bhubaneswar-1

No. 178 /JDCFA/SFTL, Bhubaneswar, the 27 th 01 2025

To,
Mrs. Soubhagya Laxmi Mohanty (Principal)
D.A.V. Public School
Plot No.148/1018, Basuaghai, Garage Chhack, Sisupalgarh, Puri Road, Bhubaneswar.

Sub: -Analysis report of Water sample.

Report No.	Nature/Name of sample submitted for analysis	Collected/Sent by	Reference No.& Date of Receipt
41/25	Aquaguard Water	Babaji Pradhan	Dt. of Receipt- 13.01.2025

ANALYSIS REPORT

The sample of Water falling under Regulation No. 2.10.9 of Food Safety and Standards (Food Products and Food Additive) Regulations, 2011 received on 13.01.2025 has been caused to be analyzed and the findings are as under:-


i) Sample Description: - Aquaguard Water

ii) Physical Appearance: - Water, Dirt & foreign Matter: - Nil, Other visible contaminants: -Nil

Sl. No.	Quality characteristics	Name of method of test used	Result	Prescribed standards as per a. As per provisions of the Act, and the rules and regulations made there under b. As per label declaration for proprietary food
1.	Colour	FSSAI	Agreeable	5 Hazen Units
2.	Odour	Manual	Agreeable	Agreeable
3.	Taste		Agreeable	Agreeable
4.	Turbidity		Nil	1 NTU (Max.)
5.	pH		7.0	6.5-8.5
6.	Nitrates (as NO ₃)		Nil	Not more than 45 mg/lit.
7.	Nitrites (as NO ₂)		Nil	Not more than 0.02 mg/lit.
8.	Iron (as Fe)		Nil	Not more than 0.3 mg/lit.
9.	Chloride (as Cl)		26 mg/lit	Not more than 250 mg/lit.
10.	Residual Free chlorine		Nil	Not more than 0.2 mg/lit.
11.	Sulphate (as SO ₄)		Nil	Not more than 200 mg/lit.
12.	Total Alkalinity (as HCO ₃)		58 mg/lit	Not more than 600 mg/lit.
13.	Total Hardness (as CaCO ₃)		64 mg/lit	Not more than 600 mg/lit.
14.	Total Dissolved Solids		150.20 mg/lit	Not more than 500 mg/lit.
15.	MPN of coliform group of organisms per 100ml		Absent	Absent
16.	Test for E.Coli		Negative	Negative

Remarks: - The Sample of Water conforms to the prescribed standard under FSSAct, 2006 based on the tests performed.

Dated: -
 State Food Testing Laboratory
 Bhubaneswar-1


Food Analyst
GOVT. OF ODISHA
Food Analyst
Govt. of Odisha